

<i>Requested by:</i>	DECORAL SYSTEM S.r.l. Viale del Lavoro, 5 - 37040 ARCOLE (VR)	
<i>For the sample:</i>	Painted metal sheets marked "DS 0725 IS + 2505/01":	
<i>On (date):</i> 29/06/16	<i>Date of receipt in laboratory (sample delivered by the client):</i> 30/06/16	
<i>Test date</i>	<i>From:</i> 01/07/16	<i>To:</i> 01/07/16

**DIN 51130 (06/2004) – Determination of the anti – slip properties**

**Workrooms and fields of activities with raised slip danger, walking method – ramp test**

Surface characteristics

- Smooth  
 Profiled  
 Structured  
 Rough

**RESULTS**

Average total acceptance angle:

13,3°

Movement area (cm<sup>3</sup>/dm<sup>2</sup>):

-----

**CLASSIFICATION (BGR 181 – 10/2003)**


Group of anti – slip properties:

**R10**

Movement area evaluation group:

-----

Eng. Giordana Carani  
 Technical approval



Prof. Maria Chiara Bignozzi  
 Director



*The results reported relate only to the samples tested. No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision. The reproduction of this test report is only authorized in the form of a complete photographic facsimile. Our written approval is necessary for any partial reproduction. This test report consists of 1 pages, this cover included.*